

Indoor Distribution Test Report

Spectrum Lighting Inc.

994 Jefferson Street
Fall River, MA 02721
+1.508.678.2303

Spectrum Lighting Photometric Lab

Luminaire

STT3PC 40L 35K WD XX
Nominal 3" Diameter STT tracklight

Test Number

SP-00596_16_M-40L

Test Date

4/30/2019

The results contained in this report pertain only to this IES file.

Summary of Results

Power

Input Watts	30.4 W
-------------	--------

Lumen Output

Output Lumens	2751
Efficacy	90.5 lm/W

Luminous Dimensions

0° - 180° Size	-0.23
90° - 270° Size	-0.23
Height	0

Spacing Criterion

Two luminaires, plane 0°	0.6
Two luminaires, plane 90°	0.58
Four luminaires	0.61


Full Beam Angle

0° - 180°	37°
90° - 270°	36°

IES File Header Contents

Keyword	Value
TEST	SP-00596_16_M-40L
TESTLAB	Spectrum Lighting Photometric Lab, VLS-245-981
MANUFAC	Spectrum Lighting
TESTDATE	4/30/2019
ISSUEDATE	5/28/2020
LUMCAT	STT3PC 40L 35K WD XX
LUMINAIRE	Nominal 3" Diameter STT tracklight
OTHER	Wide BeNLam, Open aperture
OTHER	Beam Angle: 37 degrees
LAMPCAT	N/A; CRI: 80+
LAMP	N/A, Philips emitter
OTHER	Total luminaire watts is approximate
OTHER	CCT Output Multipliers:
OTHER	This report prepared by Spectrum Lighting, scaled from 30L
_CRI	80+
_CCTMULT	27K x 0.96, 30K x 0.99, 40K x 1.04
_LAMPMULT	20L x 0.47, 30L x 0.73

Candela Polar Plot



Zonal Lumen Summary

Zone	Lumens	% Fixture	Zone	Lumens	% Fixture
0.00° - 10.00°	561.28	20.40%	90.00° - 100.00°	0.11	0.00%
10.00° - 20.00°	1,102.84	40.09%	100.00° - 110.00°	0.00	0.00%
20.00° - 30.00°	761.61	27.68%	100.00° - 120.00°	0.00	0.00%
30.00° - 40.00°	173.07	6.29%	120.00° - 130.00°	0.00	0.00%
40.00° - 50.00°	41.02	1.49%	130.00° - 140.00°	0.00	0.00%
50.00° - 60.00°	36.45	1.32%	140.00° - 150.00°	0.00	0.00%
60.00° - 70.00°	36.08	1.31%	150.00° - 160.00°	0.00	0.00%
70.00° - 80.00°	29.99	1.09%	160.00° - 170.00°	0.00	0.00%
80.00° - 90.00°	8.73	0.32%	170.00° - 180.00°	0.00	0.00%
0.00° - 90.00°	2,751.06	100.00%	0.00° - 180.00°	2,751.17	100.00%

Candela Distribution

	0.00°	22.50°	45.00°	67.50°	90.00°	112.50°	135.00°	157.50°	180.00°	202.50°	225.00°	247.50°	270.00°	292.50°	315.00°	337.50°	360.00°
0.00°	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67	6,395.67
2.50°	6,345.51	6,371.45	6,364.55	6,371.13	6,400.42	6,387.94	6,336.38	6,386.00	6,300.60	6,319.48	6,271.75	6,293.19	6,324.57	6,355.55	6,344.28	6,394.89	6,345.51
5.00°	6,149.53	6,108.19	6,121.87	6,110.97	6,105.34	6,110.42	6,153.95	6,106.97	6,089.28	6,034.80	5,989.41	5,998.34	6,023.53	6,094.75	6,166.31	6,136.12	6,149.53
7.50°	5,781.24	5,780.96	5,759.53	5,754.92	5,764.52	5,770.49	5,761.07	5,820.54	5,718.51	5,701.12	5,611.86	5,629.12	5,675.84	5,765.91	5,797.54	5,859.66	5,781.24
10.00°	5,313.09	5,253.85	5,230.16	5,209.05	5,211.69	5,250.62	5,308.56	5,295.65	5,247.01	5,172.47	5,091.85	5,100.22	5,131.90	5,238.59	5,357.94	5,329.31	5,313.09
12.50°	4,738.66	4,692.02	4,628.03	4,620.71	4,636.63	4,696.95	4,732.83	4,765.22	4,695.11	4,610.67	4,531.72	4,521.34	4,573.01	4,684.27	4,766.41	4,790.01	4,738.66
15.00°	4,129.82	4,039.16	3,987.17	3,958.66	4,001.02	4,076.11	4,128.73	4,151.11	4,098.55	4,003.75	3,919.30	3,922.72	3,961.75	4,062.29	4,157.65	4,168.93	4,129.82
17.50°	3,488.50	3,396.00	3,331.73	3,319.27	3,361.45	3,445.40	3,508.72	3,536.41	3,481.96	3,390.96	3,317.39	3,319.02	3,357.62	3,445.89	3,516.62	3,545.66	3,488.50
20.00°	2,866.05	2,774.84	2,737.76	2,713.97	2,767.89	2,847.40	2,885.74	2,915.86	2,855.79	2,789.32	2,727.43	2,741.27	2,774.28	2,841.44	2,893.25	2,907.95	2,866.05
22.50°	2,259.16	2,185.55	2,163.17	2,157.99	2,176.08	2,252.82	2,297.17	2,301.53	2,254.33	2,188.67	2,156.35	2,168.88	2,196.88	2,249.48	2,298.50	2,284.60	2,259.16
25.00°	1,713.47	1,658.19	1,661.12	1,666.65	1,701.33	1,734.90	1,713.46	1,730.35	1,662.96	1,648.57	1,604.34	1,618.88	1,634.35	1,680.45	1,737.33	1,735.38	1,713.47
27.50°	1,211.80	1,182.71	1,178.33	1,208.13	1,228.82	1,221.94	1,235.16	1,186.86	1,182.11	1,111.77	1,112.95	1,072.56	1,113.05	1,162.42	1,224.14	1,216.51	1,211.80
30.00°	813.15	794.33	795.57	787.71	816.32	816.52	767.28	789.49	740.08	733.08	675.03	681.09	679.66	726.74	788.92	822.17	813.15
32.50°	479.94	474.13	434.21	462.33	419.84	415.19	468.95	431.60	444.44	360.92	376.14	308.29	343.29	392.88	450.88	471.68	479.94
35.00°	273.53	254.84	255.52	233.37	250.36	253.98	181.44	242.80	191.62	218.20	184.31	183.60	184.84	201.91	225.30	268.37	273.53
37.50°	136.87	115.79	108.10	108.50	95.86	97.87	118.87	91.39	107.25	81.34	92.02	79.77	80.44	86.56	122.16	109.46	136.87
40.00°	80.60	80.18	77.92	77.28	76.85	76.87	62.77	70.32	63.12	67.34	67.50	65.79	63.17	63.77	65.55	77.24	80.60
42.50°	62.38	59.23	62.61	59.86	59.59	56.98	57.77	53.92	52.51	54.12	55.37	55.95	52.43	50.56	53.85	53.05	62.38
45.00°	53.59	54.78	55.39	53.29	54.07	52.89	52.82	51.09	48.41	49.98	50.57	53.29	50.86	47.75	46.69	48.26	53.59
47.50°	48.67	51.34	48.88	48.11	48.60	48.92	49.09	48.40	45.82	46.12	46.87	50.72	48.80	45.75	43.38	44.22	48.67
50.00°	45.62	48.90	45.88	43.89	43.40	46.09	45.36	46.06	43.44	44.38	43.74	47.83	46.14	44.53	41.89	41.72	45.62
52.50°	43.22	46.85	43.07	41.71	39.27	43.35	41.68	43.56	41.27	42.67	41.32	44.95	43.45	42.72	41.75	39.39	43.22
55.00°	41.59	45.15	42.54	40.76	39.57	41.22	38.30	40.70	39.11	41.17	39.21	42.40	40.73	40.42	39.65	37.39	41.59
57.50°	40.19	43.92	42.03	39.33	39.27	38.83	37.53	37.91	35.54	39.47	38.92	39.97	38.62	37.86	36.29	35.22	40.19
60.00°	40.15	43.03	40.62	37.64	36.92	35.10	36.59	35.22	31.86	36.85	39.34	38.87	37.09	35.10	34.78	32.76	40.15
62.50°	40.43	42.49	39.33	37.07	35.18	32.11	34.49	33.63	33.38	35.00	38.90	37.98	37.53	34.07	34.33	32.11	40.43
65.00°	41.65	42.17	40.56	37.00	35.12	32.17	32.63	33.78	34.99	36.06	38.18	38.77	39.60	34.14	34.11	33.94	41.65
67.50°	43.05	42.61	41.53	36.40	34.81	32.32	31.76	33.51	33.88	36.31	36.94	39.11	39.33	33.63	34.01	34.40	43.05
70.00°	40.63	43.44	40.79	35.62	33.99	32.71	31.21	32.76	32.86	34.56	35.58	37.71	37.56	32.83	33.23	33.38	40.63
72.50°	37.62	39.22	38.15	32.75	31.21	31.01	31.18	30.21	32.20	31.62	32.27	34.74	33.34	30.43	32.24	30.88	37.62
75.00°	33.14	33.65	32.24	29.03	26.93	27.48	27.88	26.69	27.28	27.61	28.46	29.69	28.99	27.62	28.34	27.66	33.14
77.50°	28.96	26.55	27.32	23.82	22.31	21.51	22.82	21.75	20.13	22.36	23.85	26.64	26.59	24.40	24.25	24.62	28.96
80.00°	24.42	22.37	21.64	18.18	16.42	16.66	16.39	17.91	16.74	17.65	18.71	22.26	22.46	18.62	19.81	19.98	24.42
82.50°	17.60	16.33	14.27	10.80	9.92	11.64	13.04	13.52	11.43	12.47	11.36	15.22	15.45	12.88	13.66	13.61	17.60
85.00°	7.77	7.94	7.19	4.31	4.85	5.83	4.79	6.61	5.60	6.01	6.80	6.87	7.10	6.96	6.90	6.95	7.77
87.50°	2.45	1.92	3.19	1.75	2.48	2.07	1.58	2.70	2.53	1.94	1.76	2.18	2.34	2.28	2.66	3.02	2.45
90.00°	1.08	1.97	0.95	0.00	0.49	0.00	0.00	0.00	0.00	0.00	0.00	1.43	2.21	1.50	1.37	1.74	1.08
92.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
95.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
97.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
102.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
105.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
107.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
110.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
112.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

STT3PC 40L 35K WD XX

Coefficients of Utilization – Zonal Cavity Method

Values are lumens delivered to the workplane.

RCR	pfc	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	0%
	pcc	80%	80%	80%	80%	70%	70%	70%	70%	50%	50%	50%	30%	30%	30%	10%	10%	0%
	pw	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	30%
	0	3,275	3,275	3,275	3,275	3,199	3,199	3,199	3,199	3,057	3,057	3,057	2,927	2,927	2,927	2,807	2,807	2,751
	1	3,134	3,063	2,999	2,941	3,067	3,004	2,947	2,895	2,893	2,847	2,806	2,791	2,755	2,722	2,697	2,670	2,617
	2	3,001	2,879	2,778	2,694	2,941	2,832	2,741	2,664	2,744	2,670	2,606	2,663	2,603	2,550	2,589	2,540	2,491
	3	2,876	2,719	2,598	2,501	2,824	2,682	2,571	2,481	2,611	2,518	2,442	2,546	2,469	2,404	2,486	2,422	2,368
	4	2,760	2,579	2,446	2,344	2,714	2,548	2,425	2,330	2,491	2,386	2,303	2,438	2,349	2,277	2,389	2,314	2,252
	5	2,652	2,453	2,315	2,212	2,611	2,429	2,299	2,203	2,382	2,270	2,184	2,338	2,241	2,165	2,297	2,214	2,147
	6	2,550	2,340	2,200	2,098	2,513	2,320	2,188	2,091	2,281	2,165	2,078	2,245	2,142	2,064	2,211	2,121	2,051
	7	2,455	2,238	2,097	1,998	2,422	2,221	2,087	1,993	2,188	2,069	1,983	2,157	2,052	1,973	2,129	2,035	1,963
	8	2,366	2,144	2,004	1,908	2,336	2,129	1,997	1,904	2,102	1,982	1,897	2,076	1,968	1,889	2,051	1,954	1,882
	9	2,282	2,057	1,920	1,827	2,255	2,045	1,914	1,824	2,021	1,902	1,818	1,999	1,891	1,813	1,978	1,879	1,807
	10	2,203	1,977	1,843	1,753	2,178	1,967	1,838	1,751	1,946	1,828	1,746	1,927	1,819	1,742	1,909	1,809	1,738

Cone of Light

Mtg Height	Light Level	Beam Diameter
5.5 ft	211.4 fc	3.7 ft
6.5 ft	151.4 fc	4.4 ft
7.5 ft	113.7 fc	5.1 ft
8.0 ft	99.9 fc	5.4 ft
10.0 ft	64.0 fc	6.7 ft
12.0 ft	44.4 fc	8.1 ft
14.0 ft	32.6 fc	9.4 ft
16.0 ft	25.0 fc	10.8 ft
20.0 ft	16.0 fc	13.5 ft
24.0 ft	11.1 fc	16.2 ft
28.0 ft	8.2 fc	18.9 ft

Average Luminaire Luminance [cd/m²]

	0.00°	45.00°	90.00°
0.00°	153,936	153,936	153,936
45.00°	1,824	1,886	1,840
55.00°	1,745	1,785	1,660
65.00°	2,372	2,310	2,000
75.00°	3,082	2,998	2,504
85.00°	2,146	1,984	1,340

UGR CIE 190:2010

Ceiling reflectance		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall reflectance		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Plane reflectance		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
2H	2H	5.8	6.7	6.1	7.0	7.4	5.7	6.6	6.0	6.9	7.2
	3H	9.3	10.2	9.7	10.5	10.9	8.8	9.7	9.2	10.0	10.4
	4H	10.7	11.5	11.2	11.9	12.3	10.1	10.9	10.5	11.2	11.6
	6H	11.9	12.6	12.3	13.0	13.4	11.1	11.8	11.5	12.2	12.6
	8H	12.3	12.9	12.7	13.3	13.7	11.4	12.1	11.8	12.5	12.9
	12H	12.4	13.1	12.9	13.5	13.9	11.5	12.2	11.9	12.5	13.0
4H	2H	6.7	7.4	7.1	7.8	8.2	6.5	7.3	6.9	7.6	8.0
	3H	10.4	11.0	10.8	11.4	11.8	9.8	10.5	10.3	10.9	11.3
	4H	11.9	12.4	12.3	12.9	13.3	11.2	11.8	11.7	12.3	12.7
	6H	13.1	13.6	13.6	14.0	14.5	12.4	12.9	12.8	13.3	13.8
	8H	13.5	14.0	14.0	14.4	14.9	12.7	13.2	13.2	13.6	14.1
	12H	13.7	14.1	14.2	14.6	15.1	12.9	13.3	13.4	13.8	14.2
8H	4H	12.3	12.7	12.8	13.2	13.7	11.7	12.1	12.2	12.6	13.1
	6H	13.6	14.0	14.2	14.5	15.0	13.0	13.3	13.5	13.8	14.3
	8H	14.2	14.5	14.7	15.0	15.5	13.4	13.7	13.9	14.2	14.7
	12H	14.4	14.7	15.0	15.2	15.8	13.6	13.9	14.1	14.4	15.0
12H	4H	12.3	12.7	12.8	13.2	13.7	11.7	12.1	12.2	12.6	13.1
	6H	13.7	14.0	14.3	14.5	15.1	13.0	13.3	13.6	13.8	14.4
	8H	14.3	14.6	14.8	15.1	15.6	13.5	13.8	14.0	14.3	14.9

Corrected UGR values based on total output lumens

SHR = 1.0