

Indoor Distribution Test Report

Spectrum Lighting Inc.

994 Jefferson Street
Fall River, MA 02721
+1.508.678.2303

Spectrum Lighting Photometric Lab

Luminaire

WS3617GV 55L 35K MF2 MWI

Nom 36 inch 55L 35K GV Frosted glass jar, matte white reflector interior

Test Number

SP-01123

Test Date

5/20/2020

The results contained in this report pertain only to this IES file.

Summary of Results

Power

Input Watts	39 W
-------------	------

Lumen Output

Output Lumens	4198
Efficacy	107.64 lm/W

Luminous Dimensions

0° - 180° Size	-3
90° - 270° Size	-3
Height	0

Spacing Criterion

Two luminaires, plane 0°	1.18
Two luminaires, plane 90°	1.18
Four luminaires	1.43


Full Beam Angle

0° - 180°	121°
90° - 270°	121°

IES File Header Contents

Keyword	Value
TEST	SP-01123
TESTLAB	Spectrum Lighting Photometric Lab, VLS-245-981
MANUFAC	Spectrum Lighting
TESTDATE	5/20/2020
ISSUEDATE	5/21/2020
LUMCAT	WS3617GV 55L 35K MF2 MWI
LUMINAIRE	Nom 36 inch 55L 35K GV Frosted glass jar, matte white reflector interior
LAMPCAT	N/A
LAMP	N/A
OTHER	Total luminaire wattage is approximate
OTHER	This report prepared by Spectrum Lighting
_CRI	83+
_CCTMULT	27K x 0.97, 30K x .99, 40K x 1.03
_LAMPMULT	15L x 0.27, 27L x 0.47, 37L x 0.68

Candela Polar Plot



Zonal Lumen Summary

Zone	Lumens	% Fixture	Zone	Lumens	% Fixture
0.00° - 10.00°	148.54	3.54%	90.00° - 100.00°	0.10	0.00%
10.00° - 20.00°	393.07	9.35%	100.00° - 110.00°	0.00	0.00%
20.00° - 30.00°	588.79	14.01%	100.00° - 120.00°	0.00	0.00%
30.00° - 40.00°	747.79	17.80%	120.00° - 130.00°	0.00	0.00%
40.00° - 50.00°	868.58	20.67%	130.00° - 140.00°	0.00	0.00%
50.00° - 60.00°	871.99	20.75%	140.00° - 150.00°	0.00	0.00%
60.00° - 70.00°	460.26	10.95%	150.00° - 160.00°	0.00	0.00%
70.00° - 80.00°	103.07	2.45%	160.00° - 170.00°	0.00	0.00%
80.00° - 90.00°	19.81	0.47%	170.00° - 180.00°	0.00	0.00%
0.00° - 90.00°	4,201.90	100.00%	0.00° - 180.00°	4,202.00	100.00%

Candela Distribution

	0.00°	45.00°	90.00°
0.00°	1,552.73	1,552.73	1,552.73
2.50°	1,534.28	1,534.28	1,534.28
5.00°	1,513.16	1,513.16	1,513.16
7.50°	1,485.69	1,485.69	1,485.69
10.00°	1,457.63	1,457.63	1,457.63
12.50°	1,426.05	1,426.05	1,426.05
15.00°	1,394.34	1,394.34	1,394.34
17.50°	1,363.23	1,363.23	1,363.23
20.00°	1,332.20	1,332.20	1,332.20
22.50°	1,302.61	1,302.61	1,302.61
25.00°	1,273.56	1,273.56	1,273.56
27.50°	1,249.24	1,249.24	1,249.24
30.00°	1,225.82	1,225.82	1,225.82
32.50°	1,207.51	1,207.51	1,207.51
35.00°	1,190.13	1,190.13	1,190.13
37.50°	1,176.70	1,176.70	1,176.70
40.00°	1,162.52	1,162.52	1,162.52
42.50°	1,146.01	1,146.01	1,146.01
45.00°	1,127.07	1,127.07	1,127.07
47.50°	1,102.22	1,102.22	1,102.22
50.00°	1,072.98	1,072.98	1,072.98
52.50°	1,034.96	1,034.96	1,034.96
55.00°	989.00	989.00	989.00
57.50°	930.15	930.15	930.15
60.00°	817.97	817.97	817.97
62.50°	634.94	634.94	634.94
65.00°	456.97	456.97	456.97
67.50°	284.48	284.48	284.48
70.00°	180.00	180.00	180.00
72.50°	116.24	116.24	116.24
75.00°	91.28	91.28	91.28
77.50°	69.67	69.67	69.67
80.00°	49.50	49.50	49.50
82.50°	30.25	30.25	30.25
85.00°	14.18	14.18	14.18
87.50°	3.39	3.39	3.39
90.00°	0.76	0.76	0.76
92.50°	0.00	0.00	0.00
95.00°	0.00	0.00	0.00
97.50°	0.00	0.00	0.00
100.00°	0.00	0.00	0.00
102.50°	0.00	0.00	0.00
105.00°	0.00	0.00	0.00
107.50°	0.00	0.00	0.00
110.00°	0.00	0.00	0.00
112.50°	0.00	0.00	0.00

Coefficients of Utilization – Zonal Cavity Method

Values are lumens delivered to the workplane.

	pfc	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	0%
	pcc	80%	80%	80%	80%	70%	70%	70%	70%	50%	50%	50%	30%	30%	30%	10%	10%	0%
	pw	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	30%
RCR	0	5,002	5,002	5,002	5,002	4,886	4,886	4,886	4,886	4,669	4,669	4,669	4,470	4,470	4,470	4,288	4,288	4,202
	1	4,621	4,441	4,281	4,136	4,509	4,347	4,201	4,069	4,170	4,051	3,941	4,008	3,911	3,821	3,858	3,781	3,702
	2	4,222	3,900	3,634	3,410	4,114	3,821	3,577	3,370	3,674	3,469	3,291	3,538	3,367	3,217	3,413	3,272	3,146
	3	3,853	3,431	3,105	2,845	3,751	3,366	3,063	2,819	3,242	2,983	2,770	3,127	2,907	2,722	3,021	2,835	2,676
	4	3,524	3,036	2,679	2,406	3,429	2,981	2,647	2,389	2,876	2,586	2,356	2,779	2,528	2,324	2,689	2,473	2,293
	5	3,234	2,705	2,335	2,062	3,147	2,658	2,311	2,051	2,570	2,263	2,028	2,487	2,218	2,006	2,410	2,174	1,985
	6	2,980	2,427	2,056	1,790	2,900	2,388	2,037	1,782	2,312	1,999	1,766	2,242	1,963	1,751	2,176	1,928	1,735
	7	2,757	2,193	1,828	1,572	2,685	2,160	1,812	1,566	2,095	1,782	1,554	2,034	1,753	1,543	1,978	1,725	1,532
	8	2,561	1,995	1,639	1,395	2,496	1,966	1,627	1,390	1,911	1,602	1,381	1,858	1,578	1,373	1,809	1,555	1,364
	9	2,389	1,826	1,482	1,249	2,329	1,801	1,471	1,245	1,753	1,451	1,239	1,708	1,431	1,232	1,665	1,412	1,226
	10	2,236	1,681	1,349	1,128	2,182	1,659	1,340	1,125	1,618	1,323	1,120	1,578	1,307	1,115	1,541	1,290	1,110

Cone of Light

Mtg Height	Light Level	Beam Diameter
5.5 ft	51.3 fc	19.5 ft
6.5 ft	36.8 fc	23.0 ft
7.5 ft	27.6 fc	26.6 ft
8.0 ft	24.3 fc	28.4 ft
10.0 ft	15.5 fc	35.4 ft
12.0 ft	10.8 fc	42.5 ft
14.0 ft	7.9 fc	49.6 ft
16.0 ft	6.1 fc	56.7 ft
20.0 ft	3.9 fc	70.9 ft
24.0 ft	2.7 fc	85.1 ft
28.0 ft	2.0 fc	99.3 ft

Average Luminaire Luminance [cd/m²]

	0.00°	45.00°	90.00°
0.00°	2,364	2,364	2,364
45.00°	2,427	2,427	2,427
55.00°	2,626	2,626	2,626
65.00°	1,647	1,647	1,647
75.00°	537	537	537
85.00°	248	248	248

UGR CIE 190:2010

Ceiling reflectance		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall reflectance		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Plane reflectance		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
2H	2H	15.7	17.3	16.1	17.7	18.0	15.7	17.3	16.1	17.7	18.0
	3H	16.0	17.5	16.4	17.8	18.2	16.0	17.5	16.4	17.8	18.2
	4H	16.1	17.4	16.5	17.8	18.1	16.1	17.4	16.5	17.8	18.1
	6H	16.1	17.3	16.5	17.7	18.1	16.1	17.3	16.5	17.7	18.1
	8H	16.0	17.2	16.5	17.6	18.0	16.0	17.2	16.5	17.6	18.0
	12H	16.0	17.2	16.5	17.5	18.0	16.0	17.2	16.5	17.5	18.0
4H	2H	16.0	17.3	16.4	17.7	18.0	16.0	17.3	16.4	17.7	18.0
	3H	16.3	17.4	16.7	17.8	18.2	16.3	17.4	16.7	17.8	18.2
	4H	16.4	17.4	16.8	17.8	18.2	16.4	17.4	16.8	17.8	18.2
	6H	16.4	17.3	16.9	17.7	18.2	16.4	17.3	16.9	17.7	18.2
	8H	16.4	17.2	16.9	17.7	18.1	16.4	17.2	16.9	17.7	18.1
	12H	16.4	17.1	16.9	17.6	18.1	16.4	17.1	16.9	17.6	18.1
8H	4H	16.3	17.2	16.8	17.6	18.1	16.3	17.2	16.8	17.6	18.1
	6H	16.4	17.1	16.9	17.5	18.0	16.4	17.1	16.9	17.5	18.0
	8H	16.4	17.0	16.9	17.5	18.0	16.4	17.0	16.9	17.5	18.0
	12H	16.4	16.9	16.9	17.4	18.0	16.4	16.9	16.9	17.4	18.0
12H	4H	16.3	17.1	16.8	17.5	18.0	16.3	17.1	16.8	17.5	18.0
	6H	16.4	17.0	16.9	17.4	18.0	16.4	17.0	16.9	17.4	18.0
	8H	16.4	16.9	16.9	17.4	18.0	16.4	16.9	16.9	17.4	18.0

Corrected UGR values based on total output lumens

SHR = 1.0