

Indoor Distribution Test Report

Spectrum Lighting Inc.

994 Jefferson Street
Fall River, MA 02721
+1.508.678.2303

Spectrum Lighting Photometric Lab

Luminaire

STT3PC 40L 35K XW XX NL
Nom 3" diam Euro tracklight

Test Number

SP-00596_23

Test Date

7/10/2019

The results contained in this report pertain only to this IES file.

Summary of Results

Power

Input Watts	30.3 W
-------------	--------

Lumen Output

Output Lumens	2789
Efficacy	92.04 lm/W

Luminous Dimensions

0° - 180° Size	-0.23
90° - 270° Size	-0.23
Height	0

Spacing Criterion

Two luminaires, plane 0°	0.94
Two luminaires, plane 90°	0.95
Four luminaires	0.93


Full Beam Angle

0° - 180°	63°
90° - 270°	63°

IES File Header Contents

Keyword	Value
TEST	SP-00596_23
TESTLAB	Spectrum Lighting Photometric lab, VLS-245-981
MANUFAC	Spectrum Lighting
TESTDATE	7/10/2019
ISSUEDATE	5/28/2020
LUMCAT	STT3PC 40L 35K XW XX NL
LUMINAIRE	Nom 3" diam Euro tracklight
OTHER	Beam Angle: 62.8 degrees
OTHER	Xtra Wide beam, open aperture
LAMPCAT	N/A
LAMP	N/A, 80 CRI
OTHER	CCT Output Multipliers: 27K x 0.96, 30K x 0.99, 40K x 1.04
OTHER	Total luminaire wattage is approximate
OTHER	This report prepared by Spectrum Lighting
_CRI	80+
_CCTMULT	27K x 0.96, 30K x 0.99, 40K x 1.04
_LAMPMULT	20L x 0.47, 30L x 0.73

Candela Polar Plot



Zonal Lumen Summary

Zone	Lumens	% Fixture	Zone	Lumens	% Fixture
0.00° - 10.00°	280.23	10.02%	90.00° - 100.00°	0.14	0.00%
10.00° - 20.00°	700.31	25.05%	100.00° - 110.00°	0.00	0.00%
20.00° - 30.00°	915.44	32.74%	100.00° - 120.00°	0.00	0.00%
30.00° - 40.00°	626.22	22.40%	120.00° - 130.00°	0.00	0.00%
40.00° - 50.00°	178.93	6.40%	130.00° - 140.00°	0.00	0.00%
50.00° - 60.00°	67.71	2.42%	140.00° - 150.00°	0.00	0.00%
60.00° - 70.00°	20.42	0.73%	150.00° - 160.00°	0.00	0.00%
70.00° - 80.00°	4.55	0.16%	160.00° - 170.00°	0.00	0.00%
80.00° - 90.00°	2.05	0.07%	170.00° - 180.00°	0.00	0.00%
0.00° - 90.00°	2,795.85	100.00%	0.00° - 180.00°	2,795.99	100.00%

Candela Distribution

	0.00°	45.00°	90.00°
0.00°	2,924.70	2,924.70	2,924.70
2.50°	2,902.39	2,922.47	2,922.47
5.00°	2,842.19	2,882.95	2,882.95
7.50°	2,766.32	2,819.13	2,819.13
10.00°	2,666.10	2,732.40	2,732.40
12.50°	2,561.82	2,630.19	2,630.19
15.00°	2,451.02	2,519.08	2,519.08
17.50°	2,339.76	2,401.91	2,401.91
20.00°	2,227.76	2,283.09	2,283.09
22.50°	2,113.18	2,163.13	2,163.13
25.00°	1,994.41	2,028.57	2,028.57
27.50°	1,835.58	1,883.65	1,883.65
30.00°	1,609.89	1,652.06	1,652.06
32.50°	1,343.97	1,358.58	1,358.58
35.00°	1,009.43	1,028.87	1,028.87
37.50°	709.75	673.12	673.12
40.00°	469.89	437.87	437.87
42.50°	291.99	292.37	292.37
45.00°	221.14	203.51	203.51
47.50°	164.62	157.09	157.09
50.00°	133.83	121.45	121.45
52.50°	105.40	93.94	93.94
55.00°	81.23	70.96	70.96
57.50°	60.44	51.52	51.52
60.00°	45.81	36.82	36.82
62.50°	33.17	25.84	25.84
65.00°	24.18	17.60	17.60
67.50°	16.62	11.44	11.44
70.00°	10.84	7.22	7.22
72.50°	7.89	3.97	3.97
75.00°	6.08	3.30	3.30
77.50°	4.07	2.76	2.76
80.00°	3.15	2.19	2.19
82.50°	3.18	1.89	1.89
85.00°	2.60	1.80	1.80
87.50°	2.27	1.38	1.38
90.00°	0.00	1.34	1.34
92.50°	0.00	0.00	0.00
95.00°	0.00	0.00	0.00
97.50°	0.00	0.00	0.00
100.00°	0.00	0.00	0.00
102.50°	0.00	0.00	0.00
105.00°	0.00	0.00	0.00
107.50°	0.00	0.00	0.00
110.00°	0.00	0.00	0.00
112.50°	0.00	0.00	0.00

Coefficients of Utilization – Zonal Cavity Method

Values are lumens delivered to the workplane.

RCR	pfc	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	0%
	pcc	80%	80%	80%	80%	70%	70%	70%	70%	50%	50%	50%	30%	30%	30%	10%	10%	0%
	pw	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	30%
	0	3,329	3,329	3,329	3,329	3,251	3,251	3,251	3,251	3,107	3,107	3,107	2,974	2,974	2,974	2,853	2,853	2,796
	1	3,168	3,088	3,017	2,952	3,099	3,027	2,963	2,905	2,914	2,863	2,816	2,810	2,769	2,732	2,714	2,682	2,628
	2	3,004	2,864	2,747	2,650	2,942	2,815	2,710	2,620	2,724	2,637	2,562	2,641	2,570	2,507	2,563	2,506	2,456
	3	2,846	2,661	2,517	2,403	2,790	2,622	2,489	2,383	2,548	2,436	2,345	2,479	2,386	2,308	2,416	2,338	2,293
	4	2,696	2,478	2,318	2,196	2,645	2,446	2,297	2,183	2,385	2,257	2,157	2,328	2,219	2,131	2,276	2,183	2,142
	5	2,554	2,313	2,144	2,020	2,507	2,286	2,128	2,011	2,235	2,098	1,993	2,188	2,069	1,975	2,144	2,041	2,003
	6	2,421	2,164	1,991	1,867	2,379	2,141	1,979	1,861	2,099	1,955	1,848	2,059	1,932	1,835	2,022	1,910	1,876
	7	2,296	2,029	1,855	1,734	2,258	2,010	1,846	1,729	1,974	1,827	1,720	1,940	1,808	1,710	1,908	1,791	1,760
	8	2,181	1,907	1,734	1,616	2,146	1,890	1,727	1,613	1,860	1,711	1,605	1,830	1,696	1,599	1,803	1,682	1,655
	9	2,073	1,796	1,626	1,511	2,042	1,782	1,620	1,509	1,755	1,607	1,503	1,730	1,595	1,498	1,706	1,583	1,559
	10	1,974	1,695	1,528	1,417	1,945	1,683	1,523	1,415	1,660	1,513	1,411	1,638	1,503	1,407	1,617	1,493	1,471

Cone of Light

Mtg Height	Light Level	Beam Diameter
5.5 ft	96.7 fc	6.7 ft
6.5 ft	69.2 fc	7.9 ft
7.5 ft	52.0 fc	9.2 ft
8.0 ft	45.7 fc	9.8 ft
10.0 ft	29.2 fc	12.2 ft
12.0 ft	20.3 fc	14.6 ft
14.0 ft	14.9 fc	17.1 ft
16.0 ft	11.4 fc	19.5 ft
20.0 ft	7.3 fc	24.4 ft
24.0 ft	5.1 fc	29.3 ft
28.0 ft	3.7 fc	34.2 ft

Average Luminaire Luminance [cd/m²]

	0.00°	45.00°	90.00°
0.00°	757,714	757,714	757,714
45.00°	81,022	74,563	74,563
55.00°	36,689	32,050	32,050
65.00°	14,824	10,791	10,791
75.00°	6,086	3,308	3,308
85.00°	7,716	5,339	5,339

UGR CIE 190:2010

Ceiling reflectance		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall reflectance		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Plane reflectance		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
2H	2H	16.3	17.3	16.6	17.6	17.9	15.6	16.6	15.9	16.9	17.2
	3H	16.4	17.3	16.8	17.6	18.0	15.6	16.5	16.0	16.8	17.2
	4H	16.4	17.2	16.8	17.6	18.0	15.5	16.4	15.9	16.7	17.1
	6H	16.3	17.1	16.8	17.5	17.9	15.5	16.2	15.9	16.6	17.0
	8H	16.3	17.0	16.8	17.4	17.8	15.4	16.1	15.9	16.5	16.9
	12H	16.3	17.0	16.7	17.4	17.8	15.4	16.1	15.8	16.5	16.9
4H	2H	16.1	17.0	16.5	17.3	17.7	15.5	16.3	15.9	16.7	17.0
	3H	16.3	17.0	16.7	17.4	17.8	15.5	16.2	16.0	16.6	17.0
	4H	16.3	16.9	16.7	17.3	17.8	15.5	16.1	15.9	16.5	16.9
	6H	16.3	16.8	16.7	17.2	17.7	15.4	15.9	15.9	16.4	16.9
	8H	16.3	16.7	16.7	17.2	17.7	15.4	15.9	15.9	16.3	16.8
	12H	16.3	16.7	16.8	17.2	17.7	15.4	15.8	15.9	16.3	16.7
8H	4H	16.2	16.6	16.6	17.1	17.6	15.3	15.8	15.8	16.3	16.7
	6H	16.1	16.5	16.6	17.0	17.5	15.3	15.7	15.8	16.2	16.7
	8H	16.1	16.5	16.7	17.0	17.5	15.3	15.6	15.8	16.1	16.6
	12H	16.2	16.5	16.7	17.0	17.6	15.3	15.6	15.8	16.1	16.7
12H	4H	16.1	16.5	16.6	17.0	17.5	15.3	15.7	15.8	16.2	16.7
	6H	16.1	16.4	16.6	16.9	17.4	15.2	15.6	15.8	16.0	16.6
	8H	16.1	16.4	16.6	16.9	17.5	15.2	15.5	15.8	16.0	16.6

Corrected UGR values based on total output lumens

SHR = 1.0