

Indoor Distribution Test Report

Spectrum Lighting Inc.

994 Jefferson Street
Fall River, MA 02721
+1.508.678.2303

Spectrum Lighting Photometric Lab

Luminaire

SGE10BX 80L 35K ND DO101 AR10BX SG WF
Nom. 10" Diam x 10" H, Open aperture

Test Number

SP-00683_5

Test Date

The results contained in this report pertain only to this IES file.

Summary of Results

Power

Input Watts	60 W
-------------	------

Lumen Output

Output Lumens	6603
Efficacy	110.05 lm/W

Luminous Dimensions

0° - 180° Size	-0.8
90° - 270° Size	-0.8
Height	0

Spacing Criterion

Two luminaires, plane 0°	0.42
Two luminaires, plane 90°	0.41
Four luminaires	0.43


Full Beam Angle

0° - 180°	25°
90° - 270°	25°

IES File Header Contents

Keyword	Value
TEST	SP-00683_5
TESTLAB	Spectrum Lighting Photometric Lab, VLS-245-981
MANUFAC	Spectrum Lighting
ISSUEDATE	6/7/2018
UPDATE	9/26/2019
LUMCAT	SGE10BX 80L 35K ND DO101 AR10BX SG WF
LUMINAIRE	Nom. 10" Diam x 10" H, Open aperture
OTHER	Semi-diffuse clear anodized alum. reflector trim
OTHER	Deep regressed retrofit high output LED downlight
OTHER	BX Series, Narrow Beam
OTHER	25 Beam Angle
LAMPCAT	N/A
LAMP	N/A, Bridgelux Vero 29
OTHER	Tested CCT: 3500K
OTHER	Total luminaire wattage is approximate
OTHER	This report prepared by Spectrum Lighting
_CCTMULT	27K x 0.932, 30K x 1.00, 40K x 1.01
_LAMPMULT	60L x 0.76, 70L x 0.86
_CRI	80

Candela Polar Plot



Zonal Lumen Summary

Zone	Lumens	% Fixture	Zone	Lumens	% Fixture
0.00° - 10.00°	1,708.08	25.87%	90.00° - 100.00°	0.12	0.00%
10.00° - 20.00°	2,215.86	33.56%	100.00° - 110.00°	0.00	0.00%
20.00° - 30.00°	1,486.05	22.51%	100.00° - 120.00°	0.00	0.00%
30.00° - 40.00°	1,003.47	15.20%	120.00° - 130.00°	0.00	0.00%
40.00° - 50.00°	184.21	2.79%	130.00° - 140.00°	0.00	0.00%
50.00° - 60.00°	2.30	0.03%	140.00° - 150.00°	0.00	0.00%
60.00° - 70.00°	0.99	0.01%	150.00° - 160.00°	0.00	0.00%
70.00° - 80.00°	1.01	0.02%	160.00° - 170.00°	0.00	0.00%
80.00° - 90.00°	1.04	0.02%	170.00° - 180.00°	0.00	0.00%
0.00° - 90.00°	6,603.01	100.00%	0.00° - 180.00°	6,603.13	100.00%

Candela Distribution

	0.00°	22.50°	45.00°	67.50°	90.00°	112.50°	135.00°	157.50°	180.00°	202.50°	225.00°	247.50°	270.00°	292.50°	315.00°	330.00°
0.00°	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13	21,205.13
2.50°	21,038.17	20,908.80	20,838.68	20,880.82	20,956.11	20,940.25	21,059.19	20,874.48	21,103.38	21,147.10	21,207.61	21,298.17	21,405.96	21,378.82	21,224.06	21,038.17
5.00°	19,270.71	19,383.48	18,914.50	19,171.84	19,018.82	18,974.20	19,268.50	19,188.20	19,611.21	19,549.44	19,936.41	19,723.10	19,835.57	19,835.27	19,608.25	19,270.71
7.50°	17,255.06	17,343.47	16,643.31	17,110.72	16,979.86	16,936.80	17,389.23	16,891.05	17,770.71	17,505.14	18,189.21	17,839.10	18,218.25	18,254.66	17,815.02	17,255.06
10.00°	13,835.17	13,853.89	13,304.81	13,586.42	13,382.03	13,323.47	13,820.00	13,635.77	14,216.41	14,179.10	14,745.06	14,428.48	14,643.65	14,675.53	14,225.06	13,835.17
12.50°	10,234.12	10,608.80	9,756.31	10,286.45	9,889.74	9,794.72	10,189.05	9,989.58	10,828.27	10,517.67	11,439.72	10,770.70	11,069.02	11,123.30	10,746.60	10,234.12
15.00°	7,858.80	7,987.93	7,476.26	7,813.41	7,600.81	7,529.96	7,813.24	7,507.79	8,156.34	8,016.04	8,586.55	8,235.00	8,491.15	8,535.03	8,211.50	7,858.80
17.50°	5,617.33	5,793.03	5,411.35	5,658.64	5,436.34	5,371.35	5,462.49	5,457.46	5,798.43	5,789.23	6,135.35	5,857.43	5,954.51	6,013.36	5,852.53	5,617.33
20.00°	4,547.89	4,605.15	4,386.82	4,552.75	4,437.69	4,399.26	4,468.96	4,318.76	4,638.23	4,601.33	4,862.99	4,702.62	4,815.37	4,855.74	4,725.20	4,547.89
22.50°	3,579.03	3,650.70	3,511.73	3,611.99	3,508.89	3,485.50	3,487.62	3,491.34	3,635.32	3,629.48	3,799.57	3,689.90	3,710.53	3,744.53	3,694.39	3,579.03
25.00°	3,168.92	3,200.01	3,112.04	3,170.29	3,113.08	3,108.84	3,121.99	3,047.66	3,178.74	3,148.77	3,290.62	3,244.06	3,285.02	3,290.50	3,234.98	3,168.92
27.50°	2,796.52	2,797.68	2,770.97	2,757.08	2,722.49	2,734.70	2,757.36	2,721.94	2,754.20	2,756.60	2,837.32	2,853.12	2,866.26	2,846.61	2,796.42	2,796.52
30.00°	2,452.66	2,490.88	2,401.22	2,421.66	2,365.28	2,379.47	2,417.74	2,358.78	2,429.45	2,388.91	2,520.56	2,496.98	2,540.87	2,516.55	2,467.02	2,452.66
32.50°	2,110.11	2,137.87	2,028.62	2,053.40	1,994.36	2,012.21	2,071.98	1,985.32	2,074.91	2,025.09	2,166.94	2,143.41	2,205.27	2,173.82	2,112.58	2,110.11
35.00°	1,666.39	1,699.74	1,594.02	1,603.72	1,546.37	1,566.66	1,620.08	1,558.78	1,636.62	1,596.27	1,730.90	1,703.78	1,757.16	1,718.53	1,643.82	1,666.39
37.50°	1,220.15	1,266.97	1,154.42	1,167.39	1,107.95	1,127.41	1,171.76	1,118.98	1,201.03	1,158.79	1,289.75	1,259.66	1,308.29	1,263.42	1,180.11	1,220.15
40.00°	798.05	843.27	759.62	761.74	716.10	723.18	768.30	725.08	772.45	750.64	838.14	813.49	852.75	809.61	736.70	798.05
42.50°	378.68	480.00	367.43	415.05	362.46	357.15	384.93	341.30	406.67	345.69	457.42	367.25	426.05	390.52	348.37	378.68
45.00°	189.15	210.97	185.65	192.11	175.69	175.00	196.47	164.29	189.13	171.86	211.80	189.12	213.94	191.30	161.20	189.15
47.50°	5.30	41.05	11.66	37.38	24.75	24.76	27.12	26.99	34.23	18.75	45.73	15.74	29.08	21.46	15.95	47.50
50.00°	3.35	15.82	5.17	15.94	12.13	12.52	13.56	4.56	14.32	5.11	18.90	8.72	14.53	10.85	7.62	3.35
52.50°	1.47	1.42	2.08	2.00	2.32	2.71	1.70	1.65	1.03	0.83	1.98	1.85	2.18	1.96	1.36	1.47
55.00°	1.22	1.62	1.86	1.51	2.15	2.18	1.40	0.99	1.00	0.74	1.29	1.43	1.60	1.38	1.30	1.22
57.50°	0.99	1.67	1.63	1.15	1.87	1.68	1.13	0.66	0.91	0.84	1.06	1.02	1.13	0.94	1.25	0.99
60.00°	0.98	1.51	1.42	1.02	1.25	1.29	1.06	0.56	0.73	0.96	1.53	0.97	1.17	1.01	1.21	0.98
62.50°	0.96	1.29	1.21	0.87	0.78	1.01	1.02	0.48	0.70	1.09	1.56	0.93	1.17	1.06	1.12	0.96
65.00°	0.92	1.00	1.05	0.69	0.75	1.06	1.09	0.63	0.93	1.69	0.97	1.12	1.03	0.95	0.88	0.92
67.50°	0.84	0.78	0.92	0.71	0.74	1.04	1.17	0.81	0.99	2.19	0.68	1.24	0.82	0.91	0.70	0.84
70.00°	0.59	0.63	1.01	0.97	0.77	0.85	1.26	1.11	0.83	1.64	0.73	1.00	0.47	1.01	0.59	0.59
72.50°	0.41	0.83	1.13	0.85	0.84	0.71	1.14	1.29	0.89	1.40	1.21	0.76	0.47	0.95	0.65	0.41
75.00°	0.33	1.12	1.28	0.61	0.96	0.61	0.79	1.14	1.07	1.79	1.75	0.52	0.84	0.74	0.82	0.33
77.50°	0.26	1.23	1.09	0.92	1.66	1.03	0.56	1.03	0.97	1.44	1.06	0.52	0.69	0.64	1.03	0.26
80.00°	0.41	1.01	0.87	0.82	1.55	1.15	0.86	1.13	0.76	1.11	0.97	0.75	0.70	0.82	0.83	0.41
82.50°	0.96	0.79	0.68	0.72	1.03	1.04	1.19	1.39	0.67	1.04	1.26	1.12	0.86	1.26	0.68	0.96
85.00°	1.36	0.73	0.74	1.11	0.78	0.80	0.70	0.93	0.82	0.73	1.19	1.03	1.15	1.21	0.82	1.36
87.50°	0.68	1.15	1.31	0.82	0.78	0.98	0.60	1.18	1.04	0.81	0.69	0.98	1.37	1.11	0.99	0.68
90.00°	0.82	1.14	0.85	0.59	0.61	1.18	1.13	1.65	0.61	0.74	0.46	0.93	0.47	0.95	1.26	0.82
92.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
95.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
97.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
102.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
105.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
107.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
110.00°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
112.50°	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Coefficients of Utilization – Zonal Cavity Method

Values are lumens delivered to the workplane.

	pfc	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	0%
	pcc	80%	80%	80%	80%	70%	70%	70%	70%	50%	50%	50%	30%	30%	30%	10%	10%	0%
	pw	70%	50%	30%	10%	70%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	30%
RCR	0	7,861	7,861	7,861	7,861	7,678	7,678	7,678	7,678	7,337	7,337	7,337	7,025	7,025	7,025	6,738	6,738	6,603
	1	7,553	7,395	7,253	7,125	7,394	7,253	7,127	7,012	6,989	6,889	6,797	6,746	6,668	6,596	6,522	6,462	6,335
	2	7,251	6,977	6,751	6,561	7,111	6,866	6,661	6,488	6,657	6,491	6,347	6,464	6,330	6,213	6,286	6,179	6,060
	3	6,962	6,604	6,328	6,108	6,838	6,516	6,263	6,059	6,348	6,138	5,964	6,194	6,019	5,872	6,050	5,907	5,796
	4	6,687	6,270	5,964	5,731	6,577	6,198	5,916	5,697	6,062	5,822	5,632	5,936	5,733	5,568	5,819	5,648	5,545
	5	6,427	5,967	5,646	5,409	6,329	5,909	5,610	5,386	5,797	5,538	5,340	5,694	5,470	5,295	5,597	5,405	5,310
	6	6,182	5,693	5,365	5,130	6,095	5,644	5,337	5,113	5,552	5,281	5,080	5,466	5,228	5,047	5,385	5,177	5,090
	7	5,952	5,443	5,114	4,883	5,873	5,403	5,091	4,871	5,325	5,048	4,846	5,252	5,006	4,822	5,184	4,966	4,886
	8	5,735	5,215	4,888	4,663	5,665	5,181	4,870	4,654	5,115	4,835	4,635	5,053	4,802	4,618	4,995	4,769	4,695
	9	5,533	5,006	4,683	4,465	5,469	4,977	4,669	4,458	4,920	4,640	4,444	4,867	4,613	4,431	4,817	4,587	4,519
	10	5,344	4,814	4,497	4,286	5,286	4,789	4,485	4,281	4,740	4,462	4,270	4,694	4,440	4,260	4,651	4,418	4,355

Cone of Light

Mtg Height	Light Level	Beam Diameter
5.5 ft	701.0 fc	2.4 ft
6.5 ft	501.9 fc	2.9 ft
7.5 ft	377.0 fc	3.3 ft
8.0 ft	331.3 fc	3.5 ft
10.0 ft	212.1 fc	4.4 ft
12.0 ft	147.3 fc	5.3 ft
14.0 ft	108.2 fc	6.2 ft
16.0 ft	82.8 fc	7.0 ft
20.0 ft	53.0 fc	8.8 ft
24.0 ft	36.8 fc	10.6 ft
28.0 ft	27.0 fc	12.3 ft

Average Luminaire Luminance [cd/m²]

	0.00°	45.00°	90.00°
0.00°	454,089	454,089	454,089
45.00°	5,728	5,622	5,321
55.00°	46	69	80
65.00°	47	53	38
75.00°	27	106	79
85.00°	335	182	191

UGR CIE 190:2010

Ceiling reflectance		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall reflectance		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Plane reflectance		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
2H	2H	-20.5	-19.6	-20.1	-19.3	-19.0	-20.9	-20.0	-20.5	-19.7	-19.3
	3H	-19.1	-18.3	-18.7	-18.0	-17.6	-19.1	-18.3	-18.7	-18.0	-17.6
	4H	-18.4	-17.7	-18.0	-17.3	-16.9	-18.1	-17.4	-17.7	-17.0	-16.7
	6H	-17.5	-16.8	-17.0	-16.4	-16.0	-15.4	-14.7	-15.0	-14.4	-14.0
	8H	-16.1	-15.5	-15.7	-15.1	-14.7	-14.3	-13.7	-13.9	-13.3	-12.9
	12H	-13.7	-13.1	-13.2	-12.7	-12.2	-13.2	-12.6	-12.8	-12.2	-11.8
4H	2H	-20.2	-19.4	-19.8	-19.1	-18.7	-20.4	-19.6	-20.0	-19.3	-18.9
	3H	-18.2	-17.6	-17.8	-17.2	-16.8	-18.2	-17.6	-17.8	-17.2	-16.8
	4H	-16.6	-16.1	-16.2	-15.6	-15.2	-17.2	-16.6	-16.7	-16.2	-15.8
	6H	-14.9	-14.4	-14.4	-13.9	-13.5	-14.3	-13.8	-13.8	-13.4	-12.9
	8H	-13.6	-13.2	-13.1	-12.7	-12.3	-13.0	-12.6	-12.5	-12.1	-11.6
	12H	-11.5	-11.2	-11.0	-10.7	-10.2	-11.6	-11.3	-11.2	-10.8	-10.3
8H	4H	-15.7	-15.3	-15.2	-14.9	-14.4	-16.1	-15.7	-15.6	-15.2	-14.8
	6H	-13.5	-13.1	-13.0	-12.6	-12.1	-13.2	-12.9	-12.7	-12.4	-11.9
	8H	-12.1	-11.8	-11.5	-11.2	-10.7	-11.7	-11.4	-11.2	-10.9	-10.4
	12H	-10.0	-9.7	-9.5	-9.2	-8.7	-10.2	-9.9	-9.7	-9.4	-8.9
12H	4H	-15.6	-15.2	-15.1	-14.7	-14.3	-15.8	-15.5	-15.3	-15.0	-14.5
	6H	-13.3	-13.0	-12.7	-12.5	-11.9	-12.8	-12.5	-12.3	-12.0	-11.5
	8H	-11.7	-11.5	-11.2	-11.0	-10.4	-11.2	-10.9	-10.6	-10.4	-9.8

Corrected UGR values based on total output lumens

SHR = 1.0