

TSRA25 BET

2.5" Track Spot Luminaire with Regressed Arm

2.5" Diameter Track spot designed for retail, hospitality and commercial spot lighting applications.

LUMENS / WATTAGE DATA

PART NUMBER	DELIVERED LUMENS*	SYSTEM WATTS	LPW
TSRA25 13L BET	1320	14	94

*Nominal Delivered Lumens

*90CRI has same delivered lumens as original 80CRI version due to use of special trigain phosphor LED diodes

FEATURES

TSRA25 fixture delivers approximately 1300 initial lumens viz precise TIR optics. Available in four distinct beam patterns. Regressed optic produces clean beam with smooth edge and is field interchangeable to other beam angles without tools. Integral flat black baffle reduces peripheral brightness. Sturdy, regressed support arm has positive friction-grip hardware that will not sag, or rotate out of aiming position over time. Clean cylindrical housing has no exposed hardware and can rotate 359 degrees with up to 90 degree aiming from nadir. Integral on/off switch for convenience.

CONSTRUCTION

TSRA25 is constructed of die cast aluminum and fabricated steel and is finished with durable powder coat finish that can be easily cleaned and maintained.

ELECTRONICS

TSRA25 has best in class LED system with 5 MacAdam ellipse binning and 90+ CRI. Integral 120V power supply is dimmable via ELV type dimming protocol control devices (contact factory for more information).

CODE COMPLIANCE

ETL listed for dry location. Manufactured and tested to UL Standards No. 1574.


WARRANTY

5 year warranty standard. L70>60,000 hours.

PROJECT: _____

QUANTITY: _____

TYPE: _____



PRODUCT SELECTOR GUIDE

SERIES	FAMILY	LUMENS	CCT	BEAM	DIMMING	ADAPTOR	FINISH
TS	RA25	13L			E1	BET	

EXAMPLE

TS	RA25	13L	35HK	MD	E1	BET	MW
----	------	-----	------	----	----	-----	----

SERIES	FAMILY	LUMENS	CCT	BEAM	DIMMING	ADAPTOR	FINISH
TS	RA25	13L - 1320 Lm	90 CRI	XN - 20°	E1 - Electronic Driver, 120V. ELV / TRIAC Dimming.	BET - Basix 1 CIR/1 NEUT 120V	MW - Matte White
			30HK - 3000 K	ND - 26°			MB - Matte Black
			35HK - 3500 K	MD - 38°			
			40HK - 3900 K	XW - 56°			

GREEN TEXT INDICATES QUICK SHIP OPTIONS




COPYRIGHT 2023 SPECTRUM LIGHTING, INC.

TSRA25 BET

2.5" Track Spot Luminaire with Regressed Arm



FIXTURE DIMENSIONS



FINISH




PAINT TIMES


TIER	COST	AVERAGE PAINT TIME*
Tier 1 - Standard Finishes	\$	🕒
Custom Color	Contact Factory	Contact Factory

*CONTACT FACTORY FOR SPECIFIC PRODUCT LEAD TIMES



TS - RA25 - 13L - 35HK - XN - xx -xx - MW

CANDLEPOWER CURVE TEST TSRA25-3	INTENSITY CANDELA 0° AZIMUTH	ZONAL LUMENS	SINGLE UNIT: PERFORMANCE HORIZONTAL FOOTCANDLES INITIAL DOWNLIGHT ONLY				MULTIPLE UNITS: PERFORMANCE 80/50/20% REFLECTANCES HORIZONTAL FOOTCANDLES AND WATTS/SQ FT															
	0.00°	0° - 10°	499	42%	Mounting Distance	FC at Beam Center	Diameter at Beam Angle	FC at Beam Edge	Ceiling Height	Fixture Spacing	RCR 4		RCR 6									
	0.00° 6992	0° - 20°	893	75%							FC *	W/Sq. Ft.	FC *	W/Sq. Ft.								
	5.00° 6148	0° - 30°	1040	88%							14'	2'	291	3.50	274	3.53						
	10.00° 3481	0° - 40°	1098	93%							18'	4'	64	0.77	76	0.98						
	15.00° 1266	0° - 60°	1137	96%							22'	4'	72	0.87	62	0.80						
	20.00° 555	0° - 80°	1149	97%							Delivered Illuminance Rating: (DIR)		83 FC per W/Sq. Ft.		78 FC per W/Sq. Ft.							
	30.00° 157	0° - 90°	1154	97%																		
	40.00° 49	Total	1186	100%							2' Suspension Length to luminous aperture Square rooms used for multiple units: RCR 4: Length & Width = Ceiling Ht. - 4.5' x 2.50 RCR 6: Length & Width = Ceiling Ht. - 4.5' x 1.66 * Average Initial Footcandles at 2.5' Above Floor											
	50.00° 20																					
	60.00° 9																					
	70.00° 6																					
	80.00° 3																					
	90.00° 5																					
Delivered Lumens: 1186																						
Luminaire Watts: 13.71																						
LER: 86.51																						
CP at 0deg (Nadir): 6992																						
CRI:																						
Beam Angle: 19.95																						
Spacing Ratio: 0.33																						
Lumen Multiplier:																						
CCT Multiplier:																						

TS - RA25 - 13L - 35HK - ND - xx -xx - MW

CANDLEPOWER CURVE TEST TSRA25-2	INTENSITY CANDELA 0° AZIMUTH	ZONAL LUMENS	SINGLE UNIT: PERFORMANCE HORIZONTAL FOOTCANDLES INITIAL DOWNLIGHT ONLY				MULTIPLE UNITS: PERFORMANCE 80/50/20% REFLECTANCES HORIZONTAL FOOTCANDLES AND WATTS/SQ FT															
	0.00°	0° - 10°	410	34%	Mounting Distance	FC at Beam Center	Diameter at Beam Angle	FC at Beam Edge	Ceiling Height	Fixture Spacing	RCR 3		RCR 5									
	0.00° 5066	0° - 20°	935	77%							FC +	W/Sq. Ft.	FC +	W/Sq. Ft.								
	5.00° 4694	0° - 30°	1075	88%							14'	4'	77	0.87	77	0.95						
	10.00° 3486	0° - 40°	1127	93%							14'	4'	77	0.87	77	0.95						
	15.00° 1945	0° - 60°	1167	96%							22'	8'	17	0.20	15	0.18						
	20.00° 743	0° - 80°	1180	97%							Delivered Illuminance Rating: (DIR)		89 FC per W/Sq. Ft.		82 FC per W/Sq. Ft.							
	30.00° 130	0° - 90°	1185	97%																		
	40.00° 48	Total	1217	100%							2' Suspension Length to luminous aperture Square rooms used for multiple units: RCR 3: Length & Width = Ceiling Ht. - 4.5' x 3.33 RCR 5: Length & Width = Ceiling Ht. - 4.5' x 2.00 * Average Initial Footcandles at 2.5' Above Floor											
	50.00° 22																					
	60.00° 10																					
	70.00° 7																					
	80.00° 5																					
	90.00° 4																					
Delivered Lumens: 1217 Luminaire Watts: 13.65 LER: 89.16	CP at 0deg (Nadir): 5066 CRI:	Beam Angle: 26.17 Spacing Ratio: 0.43	Lumen Multiplier: CCT Multiplier:																			


HOW TO USE PERFORMANCE DATA

SINGLE UNIT		MULTIPLE UNITS	
	Cone of Light of a single, symmetrical beam luminaire. Direct initial illumination (FC) and Beam Angle diameter directly beneath fixture; shown at different distances from aperture to horizontal plane. Calculated using Inverse Square Law. $FC_H = CP \times (\cos \theta) \div D^2$ Beam Diam. = $\frac{1}{2}$ Beam Angle (Tan) x 2D • CP Candela at 0° (Nadir) • Cos θ Cosine of θ Angle • D Distance (Mounting Height AFF) • FC_H Footcandles, Horizontal • Beam Angle Cone of light to 50% max. CP • Beam Diam. Pattern of light at Beam Angle	Square grid layout of multiple luminaires in unfurnished, square rooms of different proportions (Room Cavity Ratios) with 80/50/20% room surface reflectances. 2' Suspension Length to aperture. Initial average illumination (FC) calculated at 2.5' above floor, using Zonal Cavity Method. W/Sq. Ft. of layout shown for each ceiling height and RCR. Delivered Illuminance Rating (DIR®): System performance indicator expressed as ratio of approximate initial FC per W/Sq. Ft. delivered to horizontal plane below, for the range of ceiling heights indicated. • To estimate FC for Fixture Spacing that is different than shown (do not exceed Spacing Ratio): $FC = \text{Chart Spacing}^2 \div \text{Different Spacing}^2 \times \text{Chart FC}$ • To estimate Sq. Ft. per fixture for a specific target FC: $\text{Sq. Ft.} / \text{Fixture} = \text{Chart FC} \times \text{Chart Spacing}^2 \div \text{Target FC}$ • To estimate Fixture Quantity in a room: $\text{Fixture Qty.} = \text{Sq. Ft. of Rm.} \div \text{Sq. Ft. per fixture}$ • To estimate Watts/Sq. Ft.: $W / \text{Sq. Ft.} = \text{Luminaire Watts} \times \text{Qty.} \div \text{Sq. Ft. of Rm.}$	


TSRA25 BET 2.5" Track Spot Luminaire with Regressed Arm



TS - RA25 - 13L - 35HK - MD - xx -xx - MW

CANDLEPOWER CURVE TEST TSRA25-1	INTENSITY CANDELA 0° AZIMUTH	ZONAL LUMENS	SINGLE UNIT: PERFORMANCE HORIZONTAL FOOTCANDLES INITIAL DOWNLIGHT ONLY	MULTIPLE UNITS: PERFORMANCE 80/50/20% REFLECTANCES HORIZONTAL FOOTCANDLES AND WATTS/SQ FT																																																																																																																			
	<table><tr><th>0.00°</th></tr><tr><td>0.00° 2699</td></tr><tr><td>5.00° 2592</td></tr><tr><td>10.00° 2305</td></tr><tr><td>15.00° 1827</td></tr><tr><td>20.00° 1251</td></tr><tr><td>30.00° 268</td></tr><tr><td>40.00° 65</td></tr><tr><td>50.00° 22</td></tr><tr><td>60.00° 9</td></tr><tr><td>70.00° 5</td></tr><tr><td>80.00° 5</td></tr><tr><td>90.00° 5</td></tr></table>	0.00°	0.00° 2699	5.00° 2592	10.00° 2305	15.00° 1827	20.00° 1251	30.00° 268	40.00° 65	50.00° 22	60.00° 9	70.00° 5	80.00° 5	90.00° 5	<table><tr><th>0° - 10°</th><td>240</td><td>20%</td></tr><tr><th>0° - 20°</th><td>738</td><td>61%</td></tr><tr><th>0° - 30°</th><td>1046</td><td>86%</td></tr><tr><th>0° - 40°</th><td>1122</td><td>93%</td></tr><tr><th>0° - 60°</th><td>1164</td><td>96%</td></tr><tr><th>0° - 80°</th><td>1176</td><td>97%</td></tr><tr><th>0° - 90°</th><td>1181</td><td>97%</td></tr><tr><th>Total</th><td>1212</td><td>100%</td></tr></table>	0° - 10°	240	20%	0° - 20°	738	61%	0° - 30°	1046	86%	0° - 40°	1122	93%	0° - 60°	1164	96%	0° - 80°	1176	97%	0° - 90°	1181	97%	Total	1212	100%	<table><tr><th>Mounting Distance</th><th>FC at Beam Center</th><th>Diameter at Beam Angle</th><th>FC at Beam Edge</th></tr><tr><td>8.0 ' </td><td>42 fc</td><td>5.6 ' </td><td>18 fc</td></tr><tr><td>10.0 ' </td><td>27 fc</td><td>7.0 ' </td><td>11 fc</td></tr><tr><td>12.0 ' </td><td>19 fc</td><td>8.3 ' </td><td>8 fc</td></tr><tr><td>14.0 ' </td><td>14 fc</td><td>9.7 ' </td><td>6 fc</td></tr><tr><td>16.0 ' </td><td>11 fc</td><td>11.1 ' </td><td>4 fc</td></tr><tr><td>20.0 ' </td><td>7 fc</td><td>13.9 ' </td><td>3 fc</td></tr><tr><td>24.0 ' </td><td>5 fc</td><td>16.7 ' </td><td>2 fc</td></tr><tr><td>28.0 ' </td><td>3 fc</td><td>19.5 ' </td><td>1 fc</td></tr></table>	Mounting Distance	FC at Beam Center	Diameter at Beam Angle	FC at Beam Edge	8.0 '	42 fc	5.6 '	18 fc	10.0 '	27 fc	7.0 '	11 fc	12.0 '	19 fc	8.3 '	8 fc	14.0 '	14 fc	9.7 '	6 fc	16.0 '	11 fc	11.1 '	4 fc	20.0 '	7 fc	13.9 '	3 fc	24.0 '	5 fc	16.7 '	2 fc	28.0 '	3 fc	19.5 '	1 fc	<table><tr><th>Ceiling Height</th><th>Fixture Spacing</th><th colspan="2">RCR 3</th><th colspan="2">RCR 5</th></tr><tr><th></th><th></th><th>FC +</th><th>W/Sq. Ft.</th><th>FC +</th><th>W/Sq. Ft.</th></tr><tr><td>14' </td><td>4' </td><td>75</td><td>0.87</td><td>74</td><td>0.94</td></tr><tr><td>18' </td><td>6' </td><td>29</td><td>0.33</td><td>23</td><td>0.30</td></tr><tr><td>22' </td><td>8' </td><td>17</td><td>0.20</td><td>14</td><td>0.18</td></tr><tr><td colspan="2">Delivered Illuminance Rating: (DIR)</td><td colspan="2">86 FC per W/Sq. Ft.</td><td colspan="2">78 FC per W/Sq. Ft.</td></tr><tr><td colspan="6">2' Suspension Length to luminous aperture Square rooms used for multiple units: RCR 3: Length & Width = Ceiling Ht. - 4.5' x 3.33 RCR 5: Length & Width = Ceiling Ht. - 4.5' x 2.00 * Average Initial Footcandles at 2.5' Above Floor</td></tr></table>	Ceiling Height	Fixture Spacing	RCR 3		RCR 5				FC +	W/Sq. Ft.	FC +	W/Sq. Ft.	14'	4'	75	0.87	74	0.94	18'	6'	29	0.33	23	0.30	22'	8'	17	0.20	14	0.18	Delivered Illuminance Rating: (DIR)		86 FC per W/Sq. Ft.		78 FC per W/Sq. Ft.		2' Suspension Length to luminous aperture Square rooms used for multiple units: RCR 3: Length & Width = Ceiling Ht. - 4.5' x 3.33 RCR 5: Length & Width = Ceiling Ht. - 4.5' x 2.00 * Average Initial Footcandles at 2.5' Above Floor					
0.00°																																																																																																																							
0.00° 2699																																																																																																																							
5.00° 2592																																																																																																																							
10.00° 2305																																																																																																																							
15.00° 1827																																																																																																																							
20.00° 1251																																																																																																																							
30.00° 268																																																																																																																							
40.00° 65																																																																																																																							
50.00° 22																																																																																																																							
60.00° 9																																																																																																																							
70.00° 5																																																																																																																							
80.00° 5																																																																																																																							
90.00° 5																																																																																																																							
0° - 10°	240	20%																																																																																																																					
0° - 20°	738	61%																																																																																																																					
0° - 30°	1046	86%																																																																																																																					
0° - 40°	1122	93%																																																																																																																					
0° - 60°	1164	96%																																																																																																																					
0° - 80°	1176	97%																																																																																																																					
0° - 90°	1181	97%																																																																																																																					
Total	1212	100%																																																																																																																					
Mounting Distance	FC at Beam Center	Diameter at Beam Angle	FC at Beam Edge																																																																																																																				
8.0 '	42 fc	5.6 '	18 fc																																																																																																																				
10.0 '	27 fc	7.0 '	11 fc																																																																																																																				
12.0 '	19 fc	8.3 '	8 fc																																																																																																																				
14.0 '	14 fc	9.7 '	6 fc																																																																																																																				
16.0 '	11 fc	11.1 '	4 fc																																																																																																																				
20.0 '	7 fc	13.9 '	3 fc																																																																																																																				
24.0 '	5 fc	16.7 '	2 fc																																																																																																																				
28.0 '	3 fc	19.5 '	1 fc																																																																																																																				
Ceiling Height	Fixture Spacing	RCR 3		RCR 5																																																																																																																			
		FC +	W/Sq. Ft.	FC +	W/Sq. Ft.																																																																																																																		
14'	4'	75	0.87	74	0.94																																																																																																																		
18'	6'	29	0.33	23	0.30																																																																																																																		
22'	8'	17	0.20	14	0.18																																																																																																																		
Delivered Illuminance Rating: (DIR)		86 FC per W/Sq. Ft.		78 FC per W/Sq. Ft.																																																																																																																			
2' Suspension Length to luminous aperture Square rooms used for multiple units: RCR 3: Length & Width = Ceiling Ht. - 4.5' x 3.33 RCR 5: Length & Width = Ceiling Ht. - 4.5' x 2.00 * Average Initial Footcandles at 2.5' Above Floor																																																																																																																							
Delivered Lumens: 1212 Luminaire Watts: 13.64 LER: 88.86	CP at 0deg (Nadir): 2699 CRI:	Beam Angle: 38.36 Spacing Ratio: 0.62	Lumen Multiplier: CCT Multiplier:																																																																																																																				

TS - RA25 - 13L - 35HK - XW - xx -xx - MW

CANDLEPOWER CURVE TEST TSRA25-4	INTENSITY CANDELA 0° AZIMUTH	ZONAL LUMENS	SINGLE UNIT: PERFORMANCE HORIZONTAL FOOTCANDLES INITIAL DOWNLIGHT ONLY	MULTIPLE UNITS: PERFORMANCE 80/50/20% REFLECTANCES HORIZONTAL FOOTCANDLES AND WATTS/SQ FT																																																																																																																			
	<table><tr><th>0.00°</th></tr><tr><td>0.00° 1361</td></tr><tr><td>5.00° 1348</td></tr><tr><td>10.00° 1284</td></tr><tr><td>15.00° 1179</td></tr><tr><td>20.00° 1023</td></tr><tr><td>30.00° 601</td></tr><tr><td>40.00° 174</td></tr><tr><td>50.00° 27</td></tr><tr><td>60.00° 7</td></tr><tr><td>70.00° 5</td></tr><tr><td>80.00° 4</td></tr><tr><td>90.00° 4</td></tr></table>	0.00°	0.00° 1361	5.00° 1348	10.00° 1284	15.00° 1179	20.00° 1023	30.00° 601	40.00° 174	50.00° 27	60.00° 7	70.00° 5	80.00° 4	90.00° 4	<table><tr><th>0° - 10°</th><td>127</td><td>11%</td></tr><tr><th>0° - 20°</th><td>456</td><td>39%</td></tr><tr><th>0° - 30°</th><td>829</td><td>71%</td></tr><tr><th>0° - 40°</th><td>1060</td><td>91%</td></tr><tr><th>0° - 60°</th><td>1120</td><td>96%</td></tr><tr><th>0° - 80°</th><td>1131</td><td>97%</td></tr><tr><th>0° - 90°</th><td>1136</td><td>98%</td></tr><tr><th>Total</th><td>1163</td><td>100%</td></tr></table>	0° - 10°	127	11%	0° - 20°	456	39%	0° - 30°	829	71%	0° - 40°	1060	91%	0° - 60°	1120	96%	0° - 80°	1131	97%	0° - 90°	1136	98%	Total	1163	100%	<table><tr><th>Mounting Distance</th><th>FC at Beam Center</th><th>Diameter at Beam Angle</th><th>FC at Beam Edge</th></tr><tr><td>6.0 ' </td><td>38 fc</td><td>6.4 ' </td><td>13 fc</td></tr><tr><td>8.0 ' </td><td>21 fc</td><td>8.6 ' </td><td>7 fc</td></tr><tr><td>10.0 ' </td><td>14 fc</td><td>10.7 ' </td><td>5 fc</td></tr><tr><td>12.0 ' </td><td>9 fc</td><td>12.8 ' </td><td>3 fc</td></tr><tr><td>14.0 ' </td><td>7 fc</td><td>15.0 ' </td><td>2 fc</td></tr><tr><td>16.0 ' </td><td>5 fc</td><td>17.1 ' </td><td>2 fc</td></tr><tr><td>20.0 ' </td><td>3 fc</td><td>21.4 ' </td><td>1 fc</td></tr><tr><td>24.0 ' </td><td>2 fc</td><td>25.7 ' </td><td>1 fc</td></tr></table>	Mounting Distance	FC at Beam Center	Diameter at Beam Angle	FC at Beam Edge	6.0 '	38 fc	6.4 '	13 fc	8.0 '	21 fc	8.6 '	7 fc	10.0 '	14 fc	10.7 '	5 fc	12.0 '	9 fc	12.8 '	3 fc	14.0 '	7 fc	15.0 '	2 fc	16.0 '	5 fc	17.1 '	2 fc	20.0 '	3 fc	21.4 '	1 fc	24.0 '	2 fc	25.7 '	1 fc	<table><tr><th>Ceiling Height</th><th>Fixture Spacing</th><th colspan="2">RCR 2</th><th colspan="2">RCR 4</th></tr><tr><th></th><th></th><th>FC +</th><th>W/Sq. Ft.</th><th>FC +</th><th>W/Sq. Ft.</th></tr><tr><td>14' </td><td>6' </td><td>33</td><td>0.39</td><td>29</td><td>0.39</td></tr><tr><td>18' </td><td>6' </td><td>31</td><td>0.36</td><td>22</td><td>0.30</td></tr><tr><td>22' </td><td>8' </td><td>15</td><td>0.18</td><td>13</td><td>0.18</td></tr><tr><td colspan="2">Delivered Illuminance Rating: (DIR)</td><td colspan="2">85 FC per W/Sq. Ft.</td><td colspan="2">75 FC per W/Sq. Ft.</td></tr><tr><td colspan="6">2' Suspension Length to luminous aperture Square rooms used for multiple units: RCR 2: Length & Width = Ceiling Ht. - 4.5' x 5.00 RCR 4: Length & Width = Ceiling Ht. - 4.5' x 2.50 * Average Initial Footcandles at 2.5' Above Floor</td></tr></table>	Ceiling Height	Fixture Spacing	RCR 2		RCR 4				FC +	W/Sq. Ft.	FC +	W/Sq. Ft.	14'	6'	33	0.39	29	0.39	18'	6'	31	0.36	22	0.30	22'	8'	15	0.18	13	0.18	Delivered Illuminance Rating: (DIR)		85 FC per W/Sq. Ft.		75 FC per W/Sq. Ft.		2' Suspension Length to luminous aperture Square rooms used for multiple units: RCR 2: Length & Width = Ceiling Ht. - 4.5' x 5.00 RCR 4: Length & Width = Ceiling Ht. - 4.5' x 2.50 * Average Initial Footcandles at 2.5' Above Floor					
0.00°																																																																																																																							
0.00° 1361																																																																																																																							
5.00° 1348																																																																																																																							
10.00° 1284																																																																																																																							
15.00° 1179																																																																																																																							
20.00° 1023																																																																																																																							
30.00° 601																																																																																																																							
40.00° 174																																																																																																																							
50.00° 27																																																																																																																							
60.00° 7																																																																																																																							
70.00° 5																																																																																																																							
80.00° 4																																																																																																																							
90.00° 4																																																																																																																							
0° - 10°	127	11%																																																																																																																					
0° - 20°	456	39%																																																																																																																					
0° - 30°	829	71%																																																																																																																					
0° - 40°	1060	91%																																																																																																																					
0° - 60°	1120	96%																																																																																																																					
0° - 80°	1131	97%																																																																																																																					
0° - 90°	1136	98%																																																																																																																					
Total	1163	100%																																																																																																																					
Mounting Distance	FC at Beam Center	Diameter at Beam Angle	FC at Beam Edge																																																																																																																				
6.0 '	38 fc	6.4 '	13 fc																																																																																																																				
8.0 '	21 fc	8.6 '	7 fc																																																																																																																				
10.0 '	14 fc	10.7 '	5 fc																																																																																																																				
12.0 '	9 fc	12.8 '	3 fc																																																																																																																				
14.0 '	7 fc	15.0 '	2 fc																																																																																																																				
16.0 '	5 fc	17.1 '	2 fc																																																																																																																				
20.0 '	3 fc	21.4 '	1 fc																																																																																																																				
24.0 '	2 fc	25.7 '	1 fc																																																																																																																				
Ceiling Height	Fixture Spacing	RCR 2		RCR 4																																																																																																																			
		FC +	W/Sq. Ft.	FC +	W/Sq. Ft.																																																																																																																		
14'	6'	33	0.39	29	0.39																																																																																																																		
18'	6'	31	0.36	22	0.30																																																																																																																		
22'	8'	15	0.18	13	0.18																																																																																																																		
Delivered Illuminance Rating: (DIR)		85 FC per W/Sq. Ft.		75 FC per W/Sq. Ft.																																																																																																																			
2' Suspension Length to luminous aperture Square rooms used for multiple units: RCR 2: Length & Width = Ceiling Ht. - 4.5' x 5.00 RCR 4: Length & Width = Ceiling Ht. - 4.5' x 2.50 * Average Initial Footcandles at 2.5' Above Floor																																																																																																																							
Delivered Lumens: 1163 Luminaire Watts: 13.72 LER: 84.77	CP at 0deg (Nadir): 1361 CRI:	Beam Angle: 56.26 Spacing Ratio: 0.86	Lumen Multiplier: CCT Multiplier:																																																																																																																				

HOW TO USE PERFORMANCE DATA

SINGLE UNIT	MULTIPLE UNITS
Cone of Light of a single, symmetrical beam luminaire. Direct initial illumination (FC) and Beam Angle diameter directly beneath fixture; shown at different distances from aperture to horizontal plane. Calculated using Inverse Square Law. $FC_H = CP \times (\cos \theta) \div D^2$ Beam Diam. = $\frac{1}{2}$ Beam Angle (Tan) x 2D • CP Candela at 0° (Nadir) • Cos θ Cosine of θ Angle • D Distance (Mounting Height AFF) • FC_H Footcandles, Horizontal • Beam Angle Cone of light to 50% max. CP • Beam Diam. Pattern of light at Beam Angle	Square grid layout of multiple luminaires in unfurnished, square rooms of different proportions (Room Cavity Ratios) with 80/50/20% room surface reflectances. 2' Suspension Length to aperture. Initial average illumination (FC) calculated at 2.5' above floor, using Zonal Cavity Method. W/Sq. Ft. of layout shown for each ceiling heights indicated. Delivered Illuminance Rating (DIR®): System performance indicator expressed as ratio of approximate initial FC per W/Sq. Ft. delivered to horizontal plane below, for the range of ceiling heights indicated. • To estimate FC for Fixture Spacing that is different than shown (do not exceed Spacing Ratio): $FC = \text{Chart Spacing}^2 \div \text{Different Spacing}^2 \times \text{Chart FC}$ • To estimate Sq. Ft. per fixture for a specific target FC: $\text{Sq. Ft.} / \text{Fixture} = \text{Chart FC} \times \text{Chart Spacing}^2 \div \text{Target FC}$ • To estimate Fixture Quantity in a room: $\text{Fixture Qty.} = \text{Sq. Ft. of Rm.} \div \text{Sq. Ft. per fixture}$ • To estimate Watts/Sq. Ft.: $W / \text{Sq. Ft.} = \text{Luminaire Watts} \times \text{Qty.} \div \text{Sq. Ft. of Rm.}$