

IES INDOOR REPORT**PHOTOMETRIC FILENAME : SP-00424_47 ~ C1320YKFSXT-160LXXK-WDEX-MBI.IES****DESCRIPTION INFORMATION (From Photometric File)**

IESNA:LM-63-2002

[TEST] SP-00424_47_M-160L

[TESTLAB] Photopia 2017.2.1 see: www.ltiopics.com/ies

[MANUFAC] Spectrum Lighting

[ISSUEDATE] 8/16/2017

[UPDATE] 11/06/2017

[LUMCAT] C1320YKFSXT-160L-xxK-WD-EX-MBI

[LUMINAIRE] Nom. 15" Diam. x 25" H Cylinder Downlight, Yoke Mounted, Wide Beam

[OTHER] Integral Flared 3" Matte Black (interior) Deep Snoot for Additional Cutoff

[OTHER] Nom. 13" Diam. Cylinder / Nom. 15" Diam Snoot Opening

[OTHER] Matte Black regressed faceplate w/ (4) openings for LEDXT optics

[OTHER] Four (4) LEDXT Reflector modules per Luminaire

[OTHER] 53.1 Degree Beam Angle, 87.9 Degree Field Angle

[LAMPCAT] LED 4000lm

[LAMP] N/A, 19mm

[OTHER] Total Luminaire Watts is approximate

[OTHER] LEDXT lumen output is the same for all available CCT's

[OTHER] This report prepared by Spectrum Lighting, scaled from 200L

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	12000
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	75
Total Luminaire Watts	159.6
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	0.90
Spacing Criterion (90-270)	0.90
Spacing Criterion (Diagonal)	0.88
Basic Luminous Shape	Circular
Luminous Length (0-180)	1.25 ft (Diameter)
Luminous Width (90-270)	1.25 ft (Diameter)
Luminous Height	0.00 ft

IES INDOOR REPORT**PHOTOMETRIC FILENAME : SP-00424_47 ~ C1320YKFSXT-160LXXK-WDEX-MBI.IES****LUMINANCE DATA (cd/sq.m)**

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	9276	16523	9760
55	554	323	652
65	0	0	0
75	0	0	0
85	0	0	0

PHOTOMETRIC FILENAME : SP-00424_47 ~ C1320YKFSXT-160LXXK-WDEX-MBI.IES

[illegible][illegible]

IES INDOOR REPORT**PHOTOMETRIC FILENAME : SP-00424_47 ~ C1320YKFSXT-160LXXK-WDEX-MBI.IES****ZONAL LUMEN SUMMARY**

Zone	Lumens	%Lamp	%Fixt
0-20	4840.35	N.A.	40.30
0-30	8560.25	N.A.	71.30
0-40	10922.94	N.A.	91.00
0-60	11999.71	N.A.	100.00
0-80	11999.71	N.A.	100.00
0-90	11999.71	N.A.	100.00
10-90	10722.39	N.A.	89.40
20-40	6082.59	N.A.	50.70
20-50	7057.59	N.A.	58.80
40-70	1076.77	N.A.	9.00
60-80	0.00	N.A.	0.00
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	11999.71	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	1277.32
10-20	3563.03
20-30	3719.9
30-40	2362.7
40-50	975.00
50-60	101.77
60-70	0.00
70-80	0.00
80-90	0.00
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT

PHOTOMETRIC FILENAME : SP-00424_47 ~ C1320YKFSXT-160LXXK-WDEX-MBI.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD


Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	105	105	103	101	101	100	98	98	96	95	94
2	108	103	99	96	106	102	98	95	98	95	93	95	93	91	93	91	89	87
3	103	96	91	87	101	95	90	87	92	88	85	90	87	84	88	85	83	81
4	97	90	85	80	96	89	84	80	87	82	79	85	81	78	83	80	77	76
5	93	84	79	74	91	83	78	74	82	77	73	80	76	73	78	75	72	71
6	88	79	73	69	86	78	73	69	77	72	68	75	71	68	74	70	67	66
7	84	74	68	64	82	74	68	64	72	67	64	71	67	63	70	66	63	62
8	80	70	64	60	78	70	64	60	68	63	60	67	63	59	66	62	59	58
9	76	66	60	56	75	66	60	56	65	60	56	64	59	56	63	59	56	54
10	72	63	57	53	71	62	57	53	61	56	53	61	56	53	60	56	53	51

IES INDOOR REPORT

PHOTOMETRIC FILENAME : SP-00424_47 ~ C1320YKFSXT-160LXXK-WDEX-MBI.IES

POLAR GRAPH



Maximum Candela = 14325.164 Located At Horizontal Angle = 15, Vertical Angle = 10

1 - Vertical Plane Through Horizontal Angles (0 - 180)

2 - Vertical Plane Through Horizontal Angles (45 - 225)

3 - Vertical Plane Through Horizontal Angles (90 - 270)